

Display energy certificate (DEC)



HM Government

Elsworth Primary School
Elsworth Primary School
Broad End
Elsworth
Cambridge
CB23 4JD

Operational rating

C

Certificate number: 4358-9614-6272-7392-3096

Valid until: 28 January 2035

Total useful floor area: 911 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D		
			100 ..
101-125	E		
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
January 2025	
January 2015	

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
January 2025	21	14	0
January 2015	28	24	0

Assessment details

Assessor's name	Victoria Bell
Employer/Trading name	Peter Smith Associates
Employer/Trading address	The barns, 8a Church Street, Thurlby, Bourne PE10 0EH
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	16 January 2025
Nominated date	29 January 2025

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	40.95	56.36
Typical energy use (kWh/m ² /year)	40	144.48
Energy from renewables	0%	0%

